## **TOWN OF MONROE**

1465 Orange Turnpike Monroe, NY 10950

www.monroeny.org

845-783-1900 ext. 208

## TABLE R301.2 (1) CLIMATIC AND GEOGRAPHIC DESIGN CRITERIA

GROUND		1	WIND DESIGN		SEISMIC DES	IGN	SUBJECT TO DAMAGE FROM								
SNOW LOAD°	Speed <sup>d</sup> (mph)	Topographic effects <sup>k</sup>	Special wind region'	Windborne debris zone <sup>m</sup>	CATEGOR	-	neringª	Frost line depth <sup>b</sup>	Termite	DESIGN TEMP°	ICE BARRIER UNDERLAYMENT REQUIRED <sup>h</sup>		FLOOD HAZARDS <sup>g</sup>	AIR FREEZING INDEX	MEAN ANNUAL TEMP <sup>j</sup>
30	115	NO	YES	NO	В	B SEVERE		42"	YES	6	YES		2009	990	49.6
	MANUAL J DESIGN CRITERIA"														
Elevation			Latitude	Winter heati	ng Summer coolir		Alt	titude correction factor	· Ir	Indoor design temperature		Design temperature cooling		Heating temperature difference	
581'			42°	9		86		.983		70°		75°		61°	
Cooling temperature difference		Wind	velocity heating	Wind velocity co	ooling	Coincident wet bulb		Daily range		Winter humidity		Summer humidity			
16°			15 mph	7.5 mph		72		М		55%		68%			

For SI: 1 pound per square foot = 0.0479 kPa, 1 mile per hour = 0.447 m/s

- a. Weathering may require a higher strength concrete or *grade* of masonry than necessary to satisfy the structural requirements of this code. The weathering column shall be filled in with the weathering index, "negligible," " mode rate" or "severe" for concrete as determined from Figure R301.2(3). The *grade* of masonry units shall be determined from ASTM C 34, C 55, C 62, C 73, C 90, C 129, C 145, C 216 or C 652.
- b. The frost line depth may require deeper footings than indicated in Figure R403. L (1). The jurisdiction shall fill in the frost line depth column with the minimum depth of footing below finish grade.
- c. The jurisdiction shall fill in this part of the table to indicate the need for protection depending on whether there has been a history of local subterranean termite damage.
- d. The jurisdiction shall fill in this part of the table with the wind speed from the basic wind speed map [Figure R301.2 (4) A]. Wind exposure category shall be determined on a site-specific basis in accordance with Section R301.2. I.4.
- e. The outdoor design dry-bulb temperature shall be selected from the columns of 97 1/2 —percent values for winter from Appendix D of the *International Plumbing Code*. Deviations from the Appendix D temperatures shall be permitted to reflect local climates or local weather experience as determined by the *building official*.
- f. The jurisdiction shall fill in this part of the table with the seismic design category determined from Section R30 I.2.2.1.
- g. The jurisdiction shall fill in this part of the table with (a) the date of the jurisdiction's entry into the National Flood Insurance Program (date of adoption of the first code or ordinance for management of flood hazard areas), (b) the date(s) of the Flood Insurance Study and (c) the panel numbers and dates of the currently effective FIRMs and FBFMs or other flood hazard map adopted by the authority having jurisdiction, as amended.
- h. In accordance with Sections R905. I.2, R905.4.3. I, R905.5.3.I, R905.5.3.I, R905.6.3.I, R905.7.3.I and R905.8.3.I, where there has been a history of local damage from the effects of ice damming, the *jurisdiction* shall fill in this part of the table with "NO."
- i. The *jurisdiction* shall fill in this part of the table with the JOO-year return period air freezing index (BF-days) from Figure R403.3(2)or from the 100-year(99 percent) value on the National Climatic Data Center data table "Air Freezing Index-USA Method (Base 32°F)."
- j. The jurisdiction shall fill in this part of the table with the mean annual temperature from the National Climatic Data Center data table "Air Freezing Index –USA Method (Base 32°F)."
- k. In accordance with Section R301.2.1.5, where there is local historical data documenting structural damage to buildings due to topographic wind speed-up effects, the jurisdiction shall fill in this part of the table with "YES." Otherwise, the jurisdiction shall indicate "NO" in this part of the table.
- In accordance with Figure R301.2 (4) A, where there is local historical data documenting unusual wind conditions, the *jurisdiction* shall fill in this part of the table with "YES" and identify any specific requirements. Otherwise, the *jurisdiction* shall indicate "NO" in this part of the table.
- m. In accordance with Section R301.2.1.2.1, the jurisdiction shall indicate the wind-borne debris wind zone(s). Otherwise, the jurisdiction shall indicate "NO" in this part of the table.
- n. The jurisdiction shall fill in these sections of the table to establish the design criteria using Table 1a or 1b from ACCA Manual J or established criteria determined by the jurisdiction.
- o. [NY] The ground snow loads to be used in determining the design snow loads for roofs are given in Figure R301.2(6) for sites at elevations up to 1,000 feet. Sites at elevations above 1,000 feet shall have their ground snow load increased from the mapped value by 2 psf for every 1,000 feet above 1,000 feet.