TOWN OF MONROE

1465 Orange Turnpike Monroe, NY 10950

www.townofmonroeny.gov

845-783-1900 ext. 208

TABLE R301.2 (1) CLIMATIC AND GEOGRAPHIC DESIGN CRITERIA

| GROUND SNOW LOAD° | | V | VIND DESIGN | | SEISMIC DE | SIGN | SUBJECT TO DAMAGE FROM | | | | | | | | |
|--------------------------------|---------------------------------------|----------------------------------|------------------|-----------------------|------------|---------------------|------------------------|-------------------------------|---------|---------------------------|--|----------------------------|-------------------------------|--------------------------------|----------------------------------|
| | Speed ^d (mph) | Topographic effects ^k | | | CATEGOR | | theringa | Frost line depth ^b | Termite | DESIGN TEMP° | ICE BARRIER UNDERLAYMENT REQUIRED ^h | | FLOOD HAZARDS ^g | AIR FREEZING INDEX | MEAN ANNUAL TEMP ^j |
| 30 | 115 | NO | YES | NO | В | B SEV | | 42" | YES | 6 | YES | | 2009 | 990 | 49.6 |
| | MANUAL J DESIGN CRITERIA ⁿ | | | | | | | | | | | | | | |
| Elevation | Elevation | | Latitude | Winter heating | | Summer cooling | | Altitude correction factor | | Indoor design temperature | | Design temperature cooling | | Heating temperature difference | |
| | 581′ | | 42° | 9 | | 86 | | .983 | | 70° | | 75° | | 61° | |
| Cooling temperature difference | | Wind | velocity heating | Wind velocity cooling | | Coincident wet bulb | | Daily range | | Winter humidity | | Summer humidity | | | |
| 16° | | | 15 mph | 7.5 mph | 7.5 mph 72 | | М | | | 55% | | 68% | | | |

For SI: 1 pound per square foot = 0.0479 kPa, 1 mile per hour = 0.447 m/s

- a. Weathering may require a higher strength concrete or *grade* of masonry than necessary to satisfy the structural requirements of this code. The weathering column shall be filled in with the weathering index, "negligible," "mode rate" or "severe" for concrete as determined from Figure R301.2(3). The *grade* of masonry units shall be determined from ASTM C 34, C 55, C 62, C 73, C 90, C 129, C 145, C 216 or C 652.
- b. The frost line depth may require deeper footings than indicated in Figure R403. L (1). The jurisdiction shall fill in the frost line depth column with the minimum depth of footing below finish grade.
- c. The jurisdiction shall fill in this part of the table to indicate the need for protection depending on whether there has been a history of local subterranean termite damage.
- d. The jurisdiction shall fill in this part of the table with the wind speed from the basic wind speed map [Figure R301.2 (4) A]. Wind exposure category shall be determined on a site-specific basis in accordance with Section R301.2. l.4.
- e. The outdoor design dry-bulb temperature shall be selected from the columns of 97 1/2 –percent values for winter from Appendix D of the *International Plumbing Code*. Deviations from the Appendix D temperatures shall be permitted to reflect local climates or local weather experience as determined by the *building official*.
- f. The jurisdiction shall fill in this part of the table with the seismic design category determined from Section R30 I.2.2.1.
- g. The jurisdiction shall fill in this part of the table with (a) the date of the jurisdiction's entry into the National Flood Insurance Program (date of adoption of the first code or ordinance for management of flood hazard areas), (b) the date(s) of the Flood Insurance Study and (c) the panel numbers and dates of the currently effective FIRMs and FBFMs or other flood hazard map adopted by the authority having jurisdiction, as amended.
- h. In accordance with Sections R905. I.2, R905.4.3. I, R905.5.3.I, R905.5.3.I, R905.6.3.I, R905.7.3.I and R905.8.3.I, where there has been a history of local damage from the effects of ice damming, the *jurisdiction* shall fill in this part of the table with "NO."
- i. The *jurisdiction* shall fill in this part of the table with the JOO-year return period air freezing index (BF-days) from Figure R403.3(2)or from the 100-year(99 percent) value on the National Climatic Data Center data table "Air Freezing Index-USA Method (Base 32°F)."
- i. The jurisdiction shall fill in this part of the table with the mean annual temperature from the National Climatic Data Center data table "Air Freezing Index –USA Method (Base 32°F)."
- k. In accordance with Section R301.2.1.5, where there is local historical data documenting structural damage to buildings due to topographic wind speed-up effects, the jurisdiction shall fill in this part of the table with "YES." Otherwise, the jurisdiction shall indicate "NO" in this part of the table.
- I. In accordance with Figure R301.2 (4) A, where there is local historical data documenting unusual wind conditions, the *jurisdiction* shall fill in this part of the table with "YES" and identify any specific requirements. Otherwise, the *jurisdiction* shall indicate "NO" in this part of the table.
- m. In accordance with Section R301.2.1.2.1, the jurisdiction shall indicate the wind-borne debris wind zone(s). Otherwise, the jurisdiction shall indicate "NO" in this part of the table.
- n. The jurisdiction shall fill in these sections of the table to establish the design criteria using Table 1a or 1b from ACCA Manual J or established criteria determined by the jurisdiction.
- o. [NY] The ground snow loads to be used in determining the design snow loads for roofs are given in Figure R301.2(6) for sites at elevations up to 1,000 feet. Sites at elevations above 1,000 feet shall have their ground snow load increased from the mapped value by 2 psf for every 1,000 feet above 1,000 feet.